



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

**MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION**

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786)315-2590 F (786) 315-2599

www.miamidade.gov/economy

GAF

**1 Campus Drive
Parsippany, NJ 07054**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER -Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: VersaShield® Fire-Resistant Roof Deck Protection and VersaShield® Solo™ Fire-Resistant Slip Sheet

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA No. 13-1104.06 consists of pages 1 through 3.
The submitted documentation was reviewed by Alex Tigera.



**NOA No.: 14-1022.26
Expiration Date: 02/07/17
Approval Date: 02/05/15
Page 1 of 3**

ROOFING ASSEMBLY APPROVAL

Category: Roofing
Sub-Category: Underlayment
Material: Fiberglass

SCOPE:

This acceptance is for **VersaShield® Fire-Resistant Roof Deck Protection** (a.k.a “VersaShield® Underlayment”) and **VersaShield® Solo™ Fire-Resistant Slip Sheet** (a.k.a “VersaShield Solo™”), as described in this Notice of Acceptance, for use with approved prepared roof assemblies. Designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

PRODUCT DESCRIPTION:

<u>Manufactured by</u> <u>Applicant</u>	<u>Dimensions</u>	<u>Test</u> <u>Specifications</u>	<u>Product</u> <u>Description</u>
VersaShield® Fire-Resistant Roof Deck Protection	42” x 100’ rolls	ASTM D 226 Type II	Non-Asphaltic fiberglass-based underlayment and/or fire barrier.
VersaShield® Solo™ Fire-Resistant Slip Sheet	72” x 166.7’ rolls	UL790	Non-Asphaltic fiberglass-based slip sheet and/or fire barrier.

MANUFACTURING LOCATION:

1. Conover, NC

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
PRI Construction Materials	GAF-270-02-02	ASTM D 226	11/15/10
	ELK-063-02-01	TAS 100	09/27/01
Underwriters Laboratories Inc.	99NK45831	UL790	03/21/00
	10NK11990	UL790	05/18/11
	R19254	ASTM D 226	09/13/01
	08CA37926	UL790	09/23/09
	08CA49140		
PRI Asphalt Technologies, Inc.	ELK-069-02-01	TAS 100	03/04/02
	BRY-003-02-01	TAS 117(B)	03/19/02
	BRY-003-02-01	TAS 114 (H)	

INSTALLATION:

1. VersaShield® Fire-Resistant Roof Deck Protection or VersaShield® Solo™ Fire-Resistant Slip Sheet shall be installed in strict compliance with applicable Building Code.
2. VersaShield® Fire-Resistant Roof Deck Protection or VersaShield® Solo™ Fire-Resistant Slip Sheet shall be installed with a minimum 4-inch head lap in a shingle layer fashion.
3. VersaShield® Fire-Resistant Roof Deck Protection shall be mechanically fastened with approved fasteners in compliance with Florida Building Code 1518.2 when used in lieu of a code prescribed ASTM D 226 Type II underlayment.

LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product
2. This acceptance is for prepared roofing applications. Minimum deck requirements shall be in compliance with applicable building code.
3. VersaShield® Fire-Resistant Roof Deck Protection shall not be left exposed as a temporary roof for longer than 30 days of application. VersaShield® Solo™ Fire-Resistant Slip Sheet shall not be left exposed to the weather.
4. VersaShield® Fire-Resistant Roof Deck Protection and VersaShield® Solo™ Fire-Resistant Slip Sheet are a component used in roof assemblies. Roof assemblies are approved under specific assembly Notice of Acceptance.
5. VersaShield® Fire-Resistant Roof Deck Protection or VersaShield® Solo™ Fire-Resistant Slip Sheet may be used with any approved roof covering Notice of Acceptance listing. VersaShield® Fire-Resistant Roof Deck Protection or VersaShield® Solo™ Fire-Resistant Slip Sheet may be used as a component part of an assembly in the Notice of Acceptance. If VersaShield® Fire-Resistant Roof Deck Protection or VersaShield® Solo™ Fire-Resistant Slip Sheet is not listed, a request may be made to the Authority Having Jurisdiction (AHJ) or the Miami-Dade County Product Control Department for approval provided that appropriate documentation is provided to detail compatibility of the products, wind uplift resistance, and fire testing results.
6. VersaShield® Fire-Resistant Roof Deck Protection and VersaShield® Solo™ Fire-Resistant Slip Sheet are a non-asphaltic underlayment that may be used as a fire barrier for prepared roof assemblies. For fire classification of specific roof assemblies using VersaShield® Fire-Resistant Roof Deck Protection or VersaShield® Solo™ Fire-Resistant Slip Sheet refer to a current Approved Roofing Materials Directory for fire ratings of this product.
7. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

LABELING:

All membranes or packaging shall bear the imprint or identifiable marking of the manufacturer's name or logo, city and state of manufacturing facility, yellow line to identify the ASTM Standard designation or logo, and the following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



BUILDING PERMIT REQUIREMENTS:

Application for building permit shall be accompanied by copies of the following:

1. This Notice of Acceptance.
2. Any other documents required by Building Official or Applicable building code in order to properly evaluate the installation of this material.

END OF THIS ACCEPTANCE



NOA No.: 14-1022.26
Expiration Date: 02/07/17
Approval Date: 02/05/15
Page 3 of 3